



Agenda Item Details

Meeting	Apr 11, 2017 - REGULAR SCHOOL BOARD MEETING
Category	Q. Finance - Consent
Subject	10. Request for Approval of Bid #2017-06, Fire Extinguisher and Kitchen Hood System Inspection
Access	Public
Type	Action (Consent)
Recommended Action	Approval of Bid #2017-06, Fire Extinguisher and Kitchen Hood System Inspection
Goals	GF-4 Maximize Resources

Public Content**Background Information:**

Florida Statutes, Florida Administrative Code and the National Fire Protection Association require that fire extinguishers and kitchen hood systems be inspected on an annual basis. A bid was prepared for these services to ensure compliance with all applicable regulations. James Copeland, Building Code Administrator, has reviewed all bid responses and concurs with the recommendation.

Educational Impact:

Helps to provide an appropriate environment which is essential to the educational process.

Strategic Plan Impact:

Supports the District's Mission Statement by providing appropriate facilities to help students master all academic standards.

Fiscal Impact:

Funding for work performed under this bid is included in the budget of the Facilities Department.

Recommendation:

Approval of Bid #2017-06, Fire Extinguisher and Kitchen Hood System Inspection, to First Coast Fire & Safety for the period of June 1, 2017 through May 31, 2018.

Action Required:

Approval of the Superintendent's recommendation.

Drafted, reviewed and submitted by:

Patrick Snodgrass, CPSM Director of Purchasing
Michael Degutis, Chief Financial Officer
Cathy Mittelstadt, Deputy Superintendent for Operations

**Sincerely,
Tim Forson
Superintendent of Schools**

Bid #2017-06 Fire Extinguisher and Kitchen Hood System Inspection April 2017.pdf (686 KB)

Administrative Content

Our adopted rules of Parliamentary Procedure, Robert's Rules, provide for a consent agenda listing several items for approval of the Board by a single motion. Most of the items listed under the consent agenda have gone through Board subcommittee review and recommendation. Documentation concerning these items has been provided to all Board members and the public in advance to assure an extensive and thorough review. Items may be removed from the consent agenda at the request of any board member.

Workflow

Workflow Mar 15, 2017 12:19 PM :: Submitted by Vicki Davenport. Routed to Vicki Davenport for approval.
Mar 15, 2017 12:19 PM :: Approved by Vicki Davenport. Routed to Patrick Snodgrass for approval.
Mar 15, 2017 2:28 PM :: Approved by Patrick Snodgrass. Routed to Gina Fallica for approval.
Mar 21, 2017 9:08 AM :: Approved by Gina Fallica. Routed to Mike Degutis for approval.
Mar 24, 2017 9:23 AM :: Approved by Mike Degutis. Routed to Vicki Davenport for approval.
Mar 27, 2017 7:47 AM :: Approved by Vicki Davenport. Routed to Cathy Mittelstadt for approval.
Mar 29, 2017 8:45 AM :: Approved by Cathy Mittelstadt. Routed to Vicki Moody for approval.
Mar 31, 2017 10:03 AM :: Approved by Vicki Moody. Routed to Tim Forson for approval.
Apr 4, 2017 12:31 PM :: Final approval by Tim Forson

Last Modified by Tim Forson on April 4, 2017



Tim Forson
Superintendent of Schools

40 Orange Street
St. Augustine, Florida 32084
(904) 547-7500
www.stjohns.k12.fl.us

SCHOOL BOARD

Beverly Slough
District 1


Tommy Allen
District 2

Bill Mignon
District 3

Kelly Barrera
District 4

Patrick Canan
District 5

Memorandum

To: Patrick Snodgrass, Director for Purchasing
From: James Copeland, Building Code Administrator 
Re: Annual Fire Extinguisher and Kitchen Hood suppression inspections
Date: February 28, 2017

I have reviewed the four bids submitted for Bid # 2017-06 Fire Extinguisher and Kitchen Hood suppression system inspection/certification. Based on the unit prices provide in the bid First Coast Fire & Safety appears to be the lowest bidder for the project.

It is my recommendation that Bid # 2017-06 be awarded to First Coast Fire & Safety. Please let me know if I can provide any further information regarding this bid.

Cc: Paul Rose, Executive Director for Facilities and Operations

Fire Extinguisher and Kitchen Hood Systems	First Coast Fire & Safety	Cintas Corporation	Able Fire Prevention of Florida	AEGIS Fire & Integrated Services, LLC
Inspection price per unit, regardless of size	\$1.75	\$11.00	\$1.95	\$15.00
Per pound price – ABC units, 6 year maintenance recharge	\$1.95	\$0.00	\$2.00	No Charge
Per pound price – BC units, 6 year maintenance recharge	\$0.00	\$0.00	\$0.00	No Charge
Recharge K class extinguisher	\$0.00	\$0.00	\$52.00	\$52.00
New fire extinguisher – 5# ABC	\$33.95	\$35.00	\$34.00	\$30.00
New fire extinguisher – 4A-60BC (10# unit)	\$55.00	\$40.00	\$55.00	\$50.00
New fire extinguisher – 40 BC	\$0.00	\$0.00	\$0.00	No Charge
New fire extinguisher – 2 gal. K class	\$140.00	\$130.00	\$135.00	\$100.00
Existing fire extinguisher – Hydro stat test dry chemical	\$0.00	\$0.00	\$0.00	No Charge
Inspection and Certification – per system	\$50.00	\$45.00	\$45.00	\$65.00
Fusible link replacement	\$5.00	\$4.00	\$5.00	\$7.50
Hydro test system cylinder	\$10.00	\$12.00	\$12.00	No Charge
Recharge wet chemical system - per gallon	\$45.00	\$40.00	\$20.00	\$50.00

Four (4) responses received. Recommend award to First Coast Fire & Safety.